


騒音分析成績表

PFAV-P265DMJ-F

測定場所: 無響音室
計器: B&K



63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
45.0	49.5	39.5	36.0	26.5	20.5	15.5	12.0	38 (dB)

