


騒音分析成績表

PFAV-P335DMJ-F

測定場所: 無響音室
計器: B&K



63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	A特性
55.0	53.5	49.0	44.0	38.0	30.5	26.5	17.5	46 (dB)

