

区分	参考・ 最終		仕様 (対策内容・測定位置等)										
日付	2008-12-16												
測定場所	-												
使用計器	-												
暗騒音	-												
			定格機外静圧：210Pa、電源：単相200V (50Hz)										
No	記号	条件	63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	Aスケール		
1		200V/50Hz	50.0	54.5	40.5	34.5	31.5	28.0	23.5	20.0	41.0		

