

区分	参考(最終)	仕様 (対策内容・測定位置等)											
日付	2009-1-16												
測定場所	—												
使用計器	—												
暗騒音	—												
		定格機外静圧：210Pa、電源：単相200V (50Hz)											
No	記号	条件	63Hz	125Hz	250Hz	500Hz	1000Hz	2000Hz	4000Hz	8000Hz	Aスケール		
1		200V/50Hz	56.0	52.5	45.0	40.5	33.5	30.0	28.0	28.0	43.0		

